

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate Issued By

BLACKBURN PAT SERVICES

Certificate Reference 1090

DETAILS OF CLIENT:

Client/
Address: ALLTRACK PROMOTIONS LTD

TEST EQUIPMENT DETAILS:

Test Equipment used
Fluke 6200 Tester
Serial Number 9723228
Tested by Mike Ward
Date 07/03/22
Retest Date 06/03/23

Number	Appliance Description	Location	Fuse rating (A)	Earth continuity	Insulation resistance	Plug, flex and body OK ?	OK to use ?
5281	Double Light Effect + Lead (A)	Col 1	T3.13A	0.09	>20MΩ	OK	PASS
5282	Double Effect+ Lead (B)	Col 1	T3.13A	0.09	>20MΩ	OK	PASS
5283	Single Light Effect + Lead (A)	Col 1	13	0.06	>20MΩ	OK	PASS
5284	Single Light Effect + Lead (B)	Col 1	13	0.06	>20MΩ	OK	PASS
5285	2 x Amplifier Speakers + Leads	Col 1	5A	0.06	>20MΩ	OK	PASS
5286	Mixer + Lead	Col 1	13	0.07	>20MΩ	OK	PASS
5287	Long Extension Lead	Col 1	13	0.18	>20MΩ	OK	PASS
5288	6 way Extension Lead x 2	Col 1	13	0.18	>20MΩ	OK	PASS
5289	Laptop PSU (1)	Col 1	5	Class 2	>20MΩ	OK	PASS
5290	Laptop PSU (1 Spare)	Col 1	5	Class 2	>20MΩ	OK	PASS
5291	Double Light Effect + Lead (A)	Col 2	T3.13A	0.09	>20MΩ	OK	PASS
5292	Double Effect+ Lead (B)	Col 2	T3.13A	0.09	>20MΩ	OK	PASS
5293	Single Light Effect + Lead (A)	Col 2	13	0.06	>20MΩ	OK	PASS
5294	Single Light Effect + Lead (B)	Col 2	13	0.06	>20MΩ	OK	PASS
5295	2 x Amplifier Speakers + Leads	Col 2	5A	0.06	>20MΩ	OK	PASS
5296	Mixer + Lead	Col 2	13	0.07	>20MΩ	OK	PASS
5297	Long Extension Lead	Col 2	13	0.18	>20MΩ	OK	PASS
5298	6 way Extension Lead x 2	Col 2	13	0.18	>20MΩ	OK	PASS
5299	Laptop PSU (1)	Col 2	5	Class 2	>20MΩ	OK	PASS
5299	Laptop PSU (1 Spare)	Col 2	5	Class 2	>20MΩ	OK	PASS
5300	Double Light Effect + Lead (A)	Col 3	T3.13A	0.09	>20MΩ	OK	PASS
5301	Double Effect+ Lead (B)	Col 3	T3.13A	0.09	>20MΩ	OK	PASS
5302	Single Light Effect + Lead (A)	Col 3	13	0.06	>20MΩ	OK	PASS
5303	Single Light Effect + Lead (B)	Col 3	13	0.06	>20MΩ	OK	PASS
5304	2 x Amplifier Speakers + Leads	Col 3	5A	0.06	>20MΩ	OK	PASS
5305	Mixer + Lead	Col 3	13	0.07	>20MΩ	OK	PASS
5306	Long Extension Lead	Col 3	13	0.18	>20MΩ	OK	PASS
5307	6 way Extension Lead x 2	Col 3	13	0.18	>20MΩ	OK	PASS
5308	Laptop PSU (1)	Col 3	5	Class 2	>20MΩ	OK	PASS
5309	Laptop PSU (1 Spare)	Col 3	5	Class 2	>20MΩ	OK	PASS

PORTABLE APPLIANCE TESTING (PAT) REPORT/CERTIFICATE

Certificate Issued By

BLACKBURN PAT SERVICES

Certificate Reference 1090

DETAILS OF CLIENT:

Client/ Address: ALLTRACK PROMOTIONS LTD

TEST EQUIPMENT DETAILS:

Test Equipment used
Fluke 6200 Tester

Serial Number 9723228

Tested by Mike Ward

Date
07/03/22

Retest Date
06/03/23[illegible]